



GOVERNMENT OF KARNATAKA

ASSISTANT EXECUTIVE ENGINEER OFFICE,

PUBLIC WORKS DEPARTMENT, SUB-DIVISION, PERIYAPATNA-571107

Phone No: 08223-274015

E-mail: aeepwdpapatna@gmail.com

To,
The Principal
Pushpa English Medium School
Periyapatna-571107

261
5/9/2024

Office Of The
Assistant Executive Engineer,
Public Works Department,
Sub division, Periyapatna-571107

Dear Sir/Madam,

Sub: - Regarding issue of Building stability certificate.

Ref: - 1) Your letter dated: - 02.09.2024


2) Additional secretary to Govt. Department of Public works, Govt. of Karnataka Ministry of Development, Bengaluru, Letter No. Lo. E. 59 TAD 2019. Dated: - 06/05/2022

3) Their office letter no. 257.: 02/09/2024

With the reference to the above you have requested in the referred letter (1) that the building of Pushpa English Medium School, Periyapatna Taluk School building having one (1) block with Ground Floor + Two upper stories has been constructed as per the safety provision of the National Building Code of India, regarding the stability of the said building, in the reference letter (2) based on the report of the Additional secretary to Govt. Department of Public works, Govt. of Karnataka Ministry of Development, Bengaluru, Letter No. Lo. E. 59 TAD 2019. Accordingly Assistant Executive Engineer Gunabharavase Sub-Division Kushalanagar has given the NDT report of the building in reference (4) that the concrete column strength is average 26.50 N/mm² (M25 grade), beam strength is average 26.50 N/mm² (M25 grade) and roof strength is average 26.50 N/mm² (M25 grade) as per concrete. Therefore, it is hereby confirmed that the building is safe as per the said report. The issued certificate is valid up to 05/09/2025.

Your Faithfully

Asst. Executive Engineer
PWD. Sub Division
Periyapatna - 571107


Assistant Executive Engineer,
Public Works Department,
Sub division, Periyapatna-571107